SIEMENS


Data sheet 5SL4232-8



Miniature circuit breaker 400 V 10kA, 2-pole, D, 32 A

Model	
product brand name	SENTRON
product designation	Miniature circuit breaker
General technical data	
number of poles	2
design of pole	2P
tripping characteristic class	D
mechanical service life (operating cycles) typical	10 000
overvoltage category	III
degree of pollution	2
Voltage	
type of voltage of the operating voltage	AC
insulation voltage (Ui)	
with multi-phase operation at AC rated value	440 V
operational current	
• at 30 °C rated value	32 A
• at 40 °C rated value	29.56 A
• at 55 °C rated value	25.48 A
at AC rated value	32 A
Supply voltage	
supply voltage at AC rated value	400 V
value range of the supply voltage frequency	50/60 Hz
operating voltage	
 with multi-phase operation at AC maximum 	440 V
at DC rated value maximum	72 V
Protection class	
protection class IP	IP20, with connected conductors
Breaking Capacity	
switching capacity current	
 according to EN 60898 rated value 	10 kA
according to IEC 60947-2 rated value	10 kA
Dissipation	
power loss [W] for rated value of the current at AC in hot operating state per pole	2.7 W
suitability for operation	Residential buildings/infrastructure
Product details	
product feature	
• halogen-free	Yes
• sealable	Yes
• silicon-free	Yes

product extension installable supplementary devices	Yes
Connections	
connectable conductor cross-section solid	
• minimum	0.75 mm²
• maximum	25 mm²
connectable conductor cross-section stranded	
• minimum	0.75 mm²
• maximum	25 mm²
connectable conductor cross-section finely stranded with core end processing	
• minimum	0.75 mm²
maximum	25 mm²
tightening torque with screw-type terminals	
• minimum	2.5 N·m
• maximum	3 N·m
Mechanical Design	
height	90 mm
width	36 mm
depth	76 mm
installation depth	70 mm
number of modular width units	2
mounting position	any
net weight	300 g
Environmental conditions	
ambient temperature during operation	
• minimum	-25 °C
maximum	55 °C
ambient temperature during storage	
• minimum	-40 °C
• maximum	75 °C
Approvals Certificates	









Confirmation





General Product Approval Test Certificates other Environment



<u>Miscellaneous</u>

<u>Miscellaneous</u>

Miscellaneous

Confirmation

Environmental Confirmations

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SL4232-8

 $Service \& Support \ (Manuals, \ Certificates, \ Characteristics, \ FAQs, ...)$

https://support.industry.siemens.com/cs/ww/en/ps/5SL4232-8

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SL4232-8

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications



last modified: 9/7/2023 🖸

4

2

5SL4	2328
Page	5/5