

VT DIGI PRO**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LCD-Display
- acc. to VDE standard,
- high peak voltage strength
- the right tester for every application

General ordering data

Version	Testing tools, 2-pole voltage tester type 1152
Order No.	9918870000
Type	VT DIGI PRO
GTIN (EAN)	4032248405756
Qty.	1 pc(s).

VT DIGI PRO

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Dimensions and weights

Depth	67 mm	Depth (inches)	2.638 inch
Height	33 mm	Height (inches)	1.299 inch
Width	264 mm	Width (inches)	10.394 inch
Weight	295 g	Net weight	440 g

Environmental Product Compliance

REACH SVHC	Lead 7439-92-1
------------	----------------

Technical data

Description of article	Voltage tester up to 1000 V / 100 Hz LCD
------------------------	--

Measuring and testing devices

AC voltage display	1 - 1,000 V	AC voltage measuring range	1 - 1,000 V
Adjustment of display backlighting	automatic	Battery type	1.5 V type AAA battery
Buzzer	Yes	Continuity test	Yes - visual + acoustic
DC voltage display	1 - 1,000 V	DC voltage measuring range	1000 V
Display	LCD digital	Frequency measurement	Yes
Frequency range, max.	400 Hz	Frequency range, min.	16 Hz
HOLD function	Yes	Input resistance, voltage	On operating the double switch $\geq 300 \text{ k}\Omega$
Insulation test	8 kV	Load switchable	Yes
Measuring range category	CAT III 1.000V / CAT IV 600V	Note	Screw-on, thicker test probes
One-handed operation	Yes	Peak voltage resistance	8 kV
Phase sequence display	Yes	Protection degree	IP65
RCD circuit breaker	The selectable load enables conscious triggering of a 30 mA RCD circuit breaker	Rated voltage, max.	1000 V AC/DC
Rated voltage, min.	1 V	Residual-current test	Yes
Resistance measurement	Yes	Test probe illumination	Yes
Test probe protection GS 38	Yes	Tested and approved according to	IEC 61243-3:2014 (DIN EN 61243-3:2015-08)
Working temperature, max.	55 °C	Working temperature, min.	-15 °C

Classifications

ETIM 6.0	EC000494	ETIM 7.0	EC000494
ETIM 8.0	EC000494	ECLASS 9.0	27-20-03-08
ECLASS 9.1	27-20-03-08	ECLASS 10.0	27-20-03-08
ECLASS 11.0	27-20-03-08		

Approvals

Approvals



ROHS

Conform

VT DIGI PRO

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 26
D-32758 Detmold
Germany

www.weidmueller.com

Technical data

Downloads

Approval/Certificate/Document of Conformity	9918870000_DECLARATION_OF_CONFORMITY.pdf
Product Change Notification	PCN-PW641010-20180410-00-A DE PCN-PW641010-20180410-00-A EN
User Documentation	BANL_manual 2pol Tester
Catalogues	Catalogues in PDF-format
Brochures	